



1090 Bristol Road
Mountainside, NJ 07092
(908) 654-8068
(800) 783-0567
Fax 908-654-8069

LEAD IN DRINKING WATER REPORT

Performed At:

Oak Street School, Ella Clarke School
Lakewood High School, Clifton Avenue School
Lakewood Middle School & Spruce Street School
Schools of Lakewood Board of Education

Performed For:

Lakewood Board of Education
Timothy Adams
200 Ramsey Avenue
Lakewood, NJ 08701

Prepared By:

LEW Corporation
181 US Highway 46
Mine Hill, NJ 07803

Phone (908) 654-8068
Fax (908) 654-8069
Website <http://www.LEWCorp.com>

Inspection Date: 7/25/2021 &
8/01/2021

Project Number: 210206

Table of Contents

Contact Information	3
Introduction	4
Sampling Methodology	4
Drinking Water Results	5
Recommendations	7
Additional Recommendations	7

Appendices


Appendix A	Exceedances
Appendix B	Recommendations
Appendix C	All results
Appendix D	Floor Plan(S)
Appendix E	Laboratory Data

Contact Information

Agency

Client Contact:	Charles DePeri
Client Name:	Lakewood Board of Education
Street Address:	200 Ramsey Avenue Lakewood, NJ 08701
Phone Number:	(732) 905-3504

Risk Assessor(s)

Site Assessor(s):	Alex Salvador
License:	NJDOH # 022779
Signature:	
Date:	August 17, 2021
E-Mail:	asalvador@lewcorp.com

Firm

Organization:	LEW Corporation
Certification #:	NJDCA 00015 E
Street:	1090 Bristol Road
City, State & Zip:	Mountainside, New Jersey 07092
Phone Number:	908-654-8068
Web Address:	http://www.lewcorp.com

Laboratory

Organization:	Environmental Hazard Services, LLC
Street:	7469 Whitepine Road
City, State & Zip:	Richmond, VA 23237
NJDEP Certification #	VA008
Phone Number:	800-347-4010

Introduction

LEW Corporation was contracted by Lakewood Board of Education to test for the presence of lead in drinking water in six schools in the district.

Sampling Methodology

LEW Corporation followed the July 13, 2016 amendments to NJAC 6A:26. Full details on sampling practices can be found in Districts Sampling Plan.

All samples were collected in 250mL wide mouth plastic containers that was prepackaged by the analytical laboratory. The sample containers may contain nitric acid, if expedited analysis is required. If not, nitric acid will be added to each sample upon arrival at the laboratory. At each sample location, the first draw sample was taken after it was determined that the water had been standing in the plumbing system for greater than eight hours but less than forty-eight hours. If second draw samples were collected, they were collecting following a flushing protocol outlined in the District's Sampling Plan.

Drinking Water Results

On July 25, 2021 and August 1, 2021 LEW Corporation collected the following number of water samples:

Oak Street School

- 46 first draw samples collected+ 1 quality control sample collected
- 0 samples above the 15ppb action level

Ella Clarke School

- 4 first draw samples collected + 1 quality control sample collected
- 0 samples above the 15ppb action level

Lakewood High School

- 25 first draw samples collected+ 1 quality control sample collected
- 1 samples above the 15ppb action level

Clifton Avenue School

- 25 first draw samples collected+ 1 quality control sample collected
- 5 samples above the 15ppb action level

Lakewood Middle School

- 25 first draw samples collected+ 1 quality control sample collected
- 1 samples above the 15ppb action level

Spruce Street School

- 40 first draw samples collected+ 1 quality control sample collected
- 10 samples above the 15ppb action level

The complete list of samples that exceeded the 15ppb limit can be found in Appendix A. The complete list of all sample results can be found in Appendix C. The laboratory results can be found in Appendix E.

Certain outlets could not or were not tested due to various reasons. The following table lists those locations and the reason why samples were not collected.

School	Sample Location	Reason for not testing.
Spruce Street School		
Spruce Street School	SSS-20 Room 19 DF 20	Removed
Spruce Street School	SSS-29 Room 26 DF 29	Very Low Flow
Spruce Street School	SSS-35 Room 31 DF 35	Removed
Spruce Street School	SSS-44 Kitchen SF 5	Eye wash station

School	Sample Location	Reason for not testing.
Lakewood Middle School		
Middle School	MS-1 Hall by Room S3	Not found
Middle School	MS-23 Gym Boy Side	Not functional
Ella Clarke School		
Ella Clark School	EC-1 DF1	Removed
Ella Clark School	EC-2 Outside Main Office	Removed
Ella Clark School	EC-3 Outside Café Dr4	Not functional
Ella Clark School	EC-9 Hall by Room 110 DF 7	Not functional
Ella Clark School	EC-10 Hall by Room 214 DF 8	Not functional
Ella Clark School	EC- 11 DF 11	Not found
Lakewood High School		
Lakewood High School	HS-5 D103 SF5	Not present
Lakewood High School	HS-6 D103 SF6	Not present
Lakewood High School	HS-7D103 SF9	Not present
Lakewood High School	HS-8 D103 SF10	Not present
Lakewood High School	HS-13 D104 SF4	Not functional
Lakewood High School	HS-14 D104 SF5	Not functional
Lakewood High School	HS-15 D104 SF6	Not functional
Lakewood High School	HS- 23 Kitchen SF7	Not functional
Lakewood High School	HS- 24 Kitchen SF8	Not functional
Lakewood High School	HS- 25 Kitchen SF9	Not present
Lakewood High School	HS- 26 Kitchen SF10	Not present
Lakewood High School	HS- 27 Kitchen SF11	Not present
Lakewood High School	HS- 28 Common Hall DF2	Not found
Lakewood High School	HS- 29 D-UP DF3	Not found
Lakewood High School	HS-32 Main Office DF7	Not functional
Lakewood High School	HS- 33 B Hall DF9	Not functional
Lakewood High School	HS-35 Girls Locker Room DF14	Not functional
Lakewood High School	HS-36 Near B109 DF15	Not functional
Lakewood High School	HS-38 Room B201 DF17	Not functional
Lakewood High School	HS-40 Security Office DF19	Not functional
Oak Street School		
Oak Street School	OS-5 Kitchen SF5	Not present
Oak Street School	OS-6 Kitchen SF6	Not present
Oak Street School	OS-7 Kitchen SF7	Not present
Oak Street School	OS-10 Nurse Office SF8	No Access
Oak Street School	OS-16 Room 106 DF7	Not present
Oak Street School	OS-25 Room 205 DF16	Not present
Oak Street School	OS-29 Room 201 DF20	Not present
Oak Street School	OS-33 TR 3 & 4 DF 25	Not present
Oak Street School	OS-34 TR 1 & 2 DF 26	Not present
Oak Street School	OS-49 B-219 DF 43	Not present
Oak Street School	OS-53 B226 DF 47	Not present
Clifton Avenue School		
Clifton Avenue School	CS-2 Room 106 DF 3	Not functional

Clifton Avenue School	CS-3 Room 106 DF4	Not functional
Clifton Avenue School	CS-11 Room 120 DF9	Removed
Clifton Avenue School	CS-17 Room 131 DF15	Not functional

Recommendations

Those outlets where the first draw sample tested below 15ppb are not considered to be elevated and no mitigation is necessary.

For those outlets where the first draw sample exceeds 15ppb the following steps are recommended:

- 1) Immediately discontinue use of the outlets.
- 2) Conduct second draw (flush) samples on these outlets to further delineate source of contamination.
- 3) Replace faucets or install lead filters up to the wall connection.

A complete list of recommendations per outlet can be found in Appendix B.

Additional Recommendations

- 1) Follow-up samples should be collected after any remediation efforts in order to determine the efficacy of the work.
- 2) Any of the inoperable/non-functioning outlets listed above that are brought back into service should be sample.
- 3) Comply with all requirements set forth in NJAC 6A:26.

Appendix A Exceedances

Building	Date Collected	Analysis Date	Sample ID	Sample Description	Concentration (ug/L) Or ppb
1 st Draw Samples					
Lakewood High School					
Lakewood High School	7/25/2021	8/02/2021	HS-8	D104 S7	47.4
Lakewood High School	7/25/2021	8/02/2021	HS-17	WF by Room A-109	40.5
Lakewood High School	7/25/2021	8/02/2021	HS-21	Boys Locker Room	48.1
Lakewood High School	7/25/2021	8/02/2021	HS-22	Math Office	31.9
Spruce Street School					
Spruce Street School	8/01/2021	8/09/2021	SSS-5	Room 5 DF5	24.2
Spruce Street School	8/01/2021	8/09/2021	SSS-7	Room 7 DF7	20.1
Spruce Street School	8/01/2021	8/09/2021	SSS-16	Room16 DF16	136
Spruce Street School	8/01/2021	8/09/2021	SSS-19	Room 20 DF19	86.8
Spruce Street School	8/01/2021	8/09/2021	SSS-27	Room 24 DF27	17.0
Spruce Street School	8/01/2021	8/09/2021	SSS-28	Room 25 DF28	201
Spruce Street School	8/01/2021	8/09/2021	SSS-32	Room 29 DF32	27.1
Spruce Street School	8/01/2021	8/09/2021	SSS-33	Room 30	25.0
Spruce Street School	8/01/2021	8/09/2021	SSS-34	Room 32	67.8
Spruce Street School	8/01/2021	8/09/2021	SSS-36	Room 34	35.2
Clifton Avenue School					
Clifton School	7/25/2021	8/02/2021	CS-7	By Room 115	90.6
Clifton School	7/25/2021	8/02/2021	CS-10	Room 119	17.9
Clifton School	7/25/2021	8/02/2021	CS-11	Room 121	38.4
Clifton School	7/25/2021	8/02/2021	CS-22	WF By Room 219	23.8
Lakewood Middle School					
Lakewood High School	7/25/2021	8/02/2021	MS-11	Hall By Room 44	35.7

Appendix B Recommendations

Building	Sample ID	Sample Description	Remediation Recommendation
Lakewood High School			
Lakewood High School		all failed outlets	Immediately discontinue use of the outlet. Conduct second draw (flush) samples on this outlet to further delineate source of contamination or Replace faucets or install lead filters up to the wall connection.
Spruce Street School		all failed outlets	
Clifton Avenue School		all failed outlets	
Lakewood Middle School		all failed outlets	
ALL RECOMMENDATIONS ARE APPLICABLE TO OUTLETS THAT EXCEEDED THE THRESHOLD OF 15PPB			

Appendix C All Results

Building	Date Collected	Analysis Date	Sample ID	Sample Description	Concentration (ug/L) Or ppb
Ella Clarke					
Ella Clarke	7/25/2021	8/02/2021	EC-5	KITCHEN SF 1	<1.00
Ella Clarke	7/25/2021	8/02/2021	EC-6	KITCHEN SF 2	6.44
Ella Clarke	7/25/2021	8/02/2021	EC-7	KITCHEN SF 3	13.2
Ella Clarke	7/25/2021	8/02/2021	EC-8	FACULTY RM SF 4	10.8
Ella Clarke	7/25/2021	8/02/2021	EC-12	STADIUM (quality control)	<1.00

Building	Date Collected	Analysis Date	Sample ID	Sample Description	Concentration (ug/L) Or ppb
Lakewood Middle School					
Middle School	7/25/2021	8/02/2021	MS-2	OUTSIDE CAFE	<1.00
Middle School	7/25/2021	8/02/2021	MS-3	KITCHEN 1S	<1.00
Middle School	7/25/2021	8/02/2021	MS-4	KITCHEN 2S	<1.00
Middle School	7/25/2021	8/02/2021	MS-5	KITCHEN 3S	<1.00
Middle School	7/25/2021	8/02/2021	MS-6	KITCHEN 4S	<1.00
Middle School	7/25/2021	8/02/2021	MS-7	KITCHEN 5S	<1.00
Middle School	7/25/2021	8/02/2021	MS-8	KITCHEN 6S	<1.00
Middle School	7/25/2021	8/02/2021	MS-9	KITCHEN IM	<1.00
Middle School	7/25/2021	8/02/2021	MS-10	HALL BY ROOM 42	2.74
Middle School	7/25/2021	8/02/2021	MS-11	HALL BY ROOM 44	35.7
Middle School	7/25/2021	8/02/2021	MS-12	GYM GIRLS SIDE	1.03
Middle School	7/25/2021	8/02/2021	MS-13	GIRLS LOCKER RM	3.33
Middle School	7/25/2021	8/02/2021	MS-14	HALL BY ROOM 16	1.62
Middle School	7/25/2021	8/02/2021	MS-15	HALL BY ROOM 6	3.17
Middle School	7/25/2021	8/02/2021	MS-16	ROOM 6S	1.18
Middle School	7/25/2021	8/02/2021	MS-17	ROOM 7BS	3.42
Middle School	7/25/2021	8/02/2021	MS-18	HALL BY 4 CORNERS	<1.00
Middle School	7/25/2021	8/02/2021	MS-19	HALL BY ROOM 10	1.08
Middle School	7/25/2021	8/02/2021	MS-20	HALL BY ROOM 21	2.69
Middle School	7/25/2021	8/02/2021	MS-21	HALL BY ROOM 25	8.05
Middle School	7/25/2021	8/02/2021	MS-22	HALL BY ROOM 27	14.1
Middle School	7/25/2021	8/02/2021	MS-23	HALL BY ROOM 12	<1.00
Middle School	7/25/2021	8/02/2021	MS-24	HALL BY ROOM 7B	1.38
Middle School	7/25/2021	8/02/2021	MS-25	HALL BY ROOM 35	1.67
Middle School	7/25/2021	8/02/2021	MS-26	STADIUM GYM (QC)	<1.00

Building	Date Collected	Analysis Date	Sample ID	Sample Description	Concentration (ug/L) Or ppb
Lakewood High School					
Lakewood High School	7/25/2021	8/02/2021	HS-1	D103 SF1	5.14
Lakewood High School	7/25/2021	8/02/2021	HS-2	D103 SF2	7.30
Lakewood High School	7/25/2021	8/02/2021	HS-3	D103 SF3	7.56
Lakewood High School	7/25/2021	8/02/2021	HS-4	D103 IM	<1.00
Lakewood High School	7/25/2021	8/02/2021	HS-5	D104 S1	1.28
Lakewood High School	7/25/2021	8/02/2021	HS-6	D103 S2	8.40
Lakewood High School	7/25/2021	8/02/2021	HS-7	D104 S3	7.80
Lakewood High School	7/25/2021	8/02/2021	HS-8	D104 S7	47.4
Lakewood High School	7/25/2021	8/02/2021	HS-9	D104 S8	7.49
Lakewood High School	7/25/2021	8/02/2021	HS-10	CAFE HALL	4.08
Lakewood High School	7/25/2021	8/02/2021	HS-11	KITCHEN SF1	<1.00
Lakewood High School	7/25/2021	8/02/2021	HS-12	KITCHEN SF2	<1.00
Lakewood High School	7/25/2021	8/02/2021	HS-13	KITCHEN SF3	<1.00
Lakewood High School	7/25/2021	8/02/2021	HS-14	KITCHEN SF4	<1.00
Lakewood High School	7/25/2021	8/02/2021	HS-15	KITCHEN SF5	2.98
Lakewood High School	7/25/2021	8/02/2021	HS-16	KITCHEN IM	<1.00
Lakewood High School	7/25/2021	8/02/2021	HS-17	WF BY ROOM A-109	40.5
Lakewood High School	7/25/2021	8/02/2021	HS-18	B HALL BY ROOM 126	<1.00
Lakewood High School	7/25/2021	8/02/2021	HS-19	GYM LOBBY 1	2.29
Lakewood High School	7/25/2021	8/02/2021	HS-20	GYM LOBBY 2	1.26
Lakewood High School	7/25/2021	8/02/2021	HS-21	BOYS LOCKER ROOM	481
Lakewood High School	7/25/2021	8/02/2021	HS-22	MATH OFFICE	31.9
Lakewood High School	7/25/2021	8/02/2021	HS-23	SCIENCE OFFICE	14.7
Lakewood High School	7/25/2021	8/02/2021	HS-24	WF BY D201	<1.00
Lakewood High School	7/25/2021	8/02/2021	HS-25	WF BY D202	5.25
Lakewood High School	7/25/2021	8/02/2021	HS-26	STADIUM (quality control)	<1.00

Building	Date Collected	Analysis Date	Sample ID	Sample Description	Concentration (ug/L) Or ppb
Oak Street School					
Oak Street School	8/01/2021	8/06/2021	OS-1	KITCHEN SF IM	<1.00
Oak Street School	8/01/2021	8/06/2021	OS-2	KITCHEN SF 1	8.73
Oak Street School	8/01/2021	8/06/2021	OS-3	KITCHEN SF 2	2.21
Oak Street School	8/01/2021	8/06/2021	OS-4	KITCHEN SF 3	<1.00
Oak Street School	8/01/2021	8/06/2021	OS-8	BY MAIN OFFICE DF 1	2.06
Oak Street School	8/01/2021	8/06/2021	OS-9	CAFETERIA DF 2	6.13
Oak Street School	8/01/2021	8/06/2021	OS-11	PE OFFICE SF 10	2.16
Oak Street School	8/01/2021	8/06/2021	OS-12	By women employee bath DF3	4.04
Oak Street School	8/01/2021	8/06/2021	OS-13	ROOM 109 DF 4	1.16
Oak Street School	8/01/2021	8/06/2021	OS-14	ROOM 108 DF 5	2.20
Oak Street School	8/01/2021	8/06/2021	OS-15	ROOM 107 DF 6	7.43
Oak Street School	8/01/2021	8/06/2021	OS-16-1	ROOM 105 DF	1.78
Oak Street School	8/01/2021	8/06/2021	OS-17	ROOM 104 DF 8	3.36
Oak Street School	8/01/2021	8/06/2021	OS-18	ROOM 103 DF 9	<1.00
Oak Street School	8/01/2021	8/06/2021	OS-19	ROOM 102 DF 10	<1.00
Oak Street School	8/01/2021	8/06/2021	OS-20	ROOM 101 DF 11	2.28
Oak Street School	8/01/2021	8/06/2021	OS-21	ROOM 208 DF 12	6.29
Oak Street School	8/01/2021	8/06/2021	OS-22	NEXT TO ELEVATOR DF 13	1.15
Oak Street School	8/01/2021	8/06/2021	OS-23	ROOM 207 DF 14	1.65
Oak Street School	8/01/2021	8/06/2021	OS-24	ROOM 206 DF 15	1.55
Oak Street School	8/01/2021	8/06/2021	OS-26	ROOM 204 DF 17	1.57
Oak Street School	8/01/2021	8/06/2021	OS-27	ROOM 203 DF 18	1.02
Oak Street School	8/01/2021	8/06/2021	OS-28	ROOM 202 DF 19	1.60
Oak Street School	8/01/2021	8/06/2021	OS-29-1	ROOM 211 DF 21	1.13
Oak Street School	8/01/2021	8/06/2021	OS-30	ROOM 210 DF 22	<1.00
Oak Street School	8/01/2021	8/06/2021	OS-31	ROOM 209 DF 23	1.69
Oak Street School	8/01/2021	8/06/2021	OS-32	2ND FL ELEVATOR DF 24	3.82
Oak Street School	8/01/2021	8/06/2021	OS-35	B 112 DF 27	<1.00
Oak Street School	8/01/2021	8/06/2021	OS-36	B 113 DF 28	<1.00
Oak Street School	8/01/2021	8/06/2021	OS-37	B 114 DF 29	<1.00
Oak Street School	8/01/2021	8/06/2021	OS-38	B 116 DF 31	<1.00
Oak Street School	8/01/2021	8/06/2021	OS-39	B 117 DF 32	<1.00

Building	Date Collected	Analysis Date	Sample ID	Sample Description	Concentration (ug/L) Or ppb
Oak Street School					
Oak Street School	8/01/2021	8/06/2021	OS-40	B 119 DF 33	<1.00
Oak Street School	8/01/2021	8/06/2021	OS-41	B 120 DF 34	<1.00
Oak Street School	8/01/2021	8/06/2021	OS-42	B 121 DF 35	<1.00
Oak Street School	8/01/2021	8/06/2021	OS-43	BY ROOM 122 DF 37	2.46
Oak Street School	8/01/2021	8/06/2021	OS-43-1	ROOM 122	<1.00
Oak Street School	8/01/2021	8/06/2021	OS-44	B ROOM 223 DF 38	<1.00
Oak Street School	8/01/2021	8/06/2021	OS-45	B 222 DF 39	<1.00
Oak Street School	8/01/2021	8/06/2021	OS-46	B BY ROOM 223 DF 40	<1.00
Oak Street School	8/01/2021	8/06/2021	OS-47	B 221 DF 41	<1.00
Oak Street School	8/01/2021	8/06/2021	OS-48	B 220 DF 42	<1.00
Oak Street School	8/01/2021	8/06/2021	OS-50	B 229 DF 44	<1.00
Oak Street School	8/01/2021	8/06/2021	OS-51	B 228 DF 45	2.70
Oak Street School	8/01/2021	8/06/2021	OS-52	B 227 DF 46	<1.00
Oak Street School	8/01/2021	8/06/2021	OS-54	B 225 DF 45	<1.00
Oak Street School	8/01/2021	8/06/2021	OS-101	STUDY HALL (quality control)	<1.00

Building	Date Collected	Analysis Date	Sample ID	Sample Description	Concentration (ug/L) Or ppb
Spruce Street School					
Spruce Street School	8/01/2021	8/09/2021	SSS-1	ROOM 1 DF 1	4.42
Spruce Street School	8/01/2021	8/09/2021	SSS 1-1	BY ROOM 1 DF	9.25
Spruce Street School	8/01/2021	8/09/2021	SSS-2	ROOM 2 DF 2	7.95
Spruce Street School	8/01/2021	8/09/2021	SSS-3	ROOM 3 DF 3	7.01
Spruce Street School	8/01/2021	8/09/2021	SSS-4	ROOM 4 DF 4	6.17
Spruce Street School	8/01/2021	8/09/2021	SSS-5	ROOM 5 DF 5	24.2
Spruce Street School	8/01/2021	8/09/2021	SSS-6	ROOM 6 DF 6	1.68
Spruce Street School	8/01/2021	8/09/2021	SSS-7	ROOM 7 DF 7	20.1
Spruce Street School	8/01/2021	8/09/2021	SSS-8	ROOM 9 DF 8	6.46
Spruce Street School	8/01/2021	8/09/2021	SSS-9	ROOM 8 DF 9	<1.00
Spruce Street School	8/01/2021	8/09/2021	SSS-10	ROOM 11 DF 10	3.55
Spruce Street School	8/01/2021	8/09/2021	SSS-11	ROOM 10 DF 11	4.66
Spruce Street School	8/01/2021	8/09/2021	SSS-12	ROOM 12 DF 12	5.54
Spruce Street School	8/01/2021	8/09/2021	SSS-13	ROOM 13 DF 13	2.14
Spruce Street School	8/01/2021	8/09/2021	SSS-14	ROOM 14 DF 14	1.12
Spruce Street School	8/01/2021	8/09/2021	SSS-15	ROOM 15 DF 15	2.03
Spruce Street School	8/01/2021	8/09/2021	SSS-16	ROOM 16 DF 16	136
Spruce Street School	8/01/2021	8/09/2021	SSS-17	ROOM 17 DF 17	7.38
Spruce Street School	8/01/2021	8/09/2021	SSS-18	ROOM 18 DF 18	12.1
Spruce Street School	8/01/2021	8/09/2021	SSS-19	ROOM 20 DF 19	86.8
Spruce Street School	8/01/2021	8/09/2021	SSS-22	ROOM 21 DF 22	7.53
Spruce Street School	8/01/2021	8/09/2021	SSS-23	ROOM 22 DF 23	6.57
Spruce Street School	8/01/2021	8/09/2021	SSS-24	ROOM 23 DF 24	<1.00
Spruce Street School	8/01/2021	8/09/2021	SSS-25	BY MENS FACULTY DF 25	1.52
Spruce Street School	8/01/2021	8/09/2021	SSS-26	BY LADIES FACULTY DF 26	7.96
Spruce Street School	8/01/2021	8/09/2021	SSS-27	ROOM 24 DF 27	17.0
Spruce Street School	8/01/2021	8/09/2021	SSS-28	ROOM 25 DF 28	201
Spruce Street School	8/01/2021	8/09/2021	SSS-30	ROOM 27 DF 30	2.43
Spruce Street School	8/01/2021	8/09/2021	SSS-31	ROOM 28 DF 31	<1.00
Spruce Street School	8/01/2021	8/09/2021	SSS-32	ROOM 29 DF 32	27.1
Spruce Street School	8/01/2021	8/09/2021	SSS-33	ROOM 30	25.0
Spruce Street School	8/01/2021	8/09/2021	SSS-34	ROOM 32	67.8
Spruce Street School	8/01/2021	8/09/2021	SSS-36	ROOM 34	35.2
Spruce Street School	8/01/2021	8/09/2021	SSS-37	ROOM 33	10.4
Spruce Street School	8/01/2021	8/09/2021	SSS-38	BY BOILER ROOM DF 38	4.83

Building	Date Collected	Analysis Date	Sample ID	Sample Description	Concentration (ug/L) Or ppb
Spruce Street School					
Spruce Street School	8/01/2021	8/09/2021	SSS-39	LUNCH ROOM DF 39	1.32
Spruce Street School	8/01/2021	8/09/2021	SSS-40	KITCHEN SF 1	4.10
Spruce Street School	8/01/2021	8/09/2021	SSS-41	KITCHEN SF 2	2.71
Spruce Street School	8/01/2021	8/09/2021	SSS-42	KITCHEN SF 3 IM	2.52
Spruce Street School	8/01/2021	8/09/2021	SSS-43	KITCHEN SF 4	1.71
Spruce Street School	8/01/2021	8/09/2021	SSS-45	KITCHEN SF 6	<1.00

Building	Date Collected	Analysis Date	Sample ID	Sample Description	Concentration (ug/L) Or ppb
Clifton Avenue School					
Clifton School	7/25/2021	8/02/2021	CS-1	BY ROOM 106	<1.00
Clifton School	7/25/2021	8/02/2021	CS-2	KITCHEN SF 1	5.20
Clifton School	7/25/2021	8/02/2021	CS-3	KITCHEN SF 2	3.62
Clifton School	7/25/2021	8/02/2021	CS-4	KITCHEN SF 4	3.05
Clifton School	7/25/2021	8/02/2021	CS-5	KITCHEN SF 5	1.89
Clifton School	7/25/2021	8/02/2021	CS-6	KITCHEN SF 6	2.96
Clifton School	7/25/2021	8/02/2021	CS-7	BY ROOM 115	90.6
Clifton School	7/25/2021	8/02/2021	CS-8	ROOM 116	9.52
Clifton School	7/25/2021	8/02/2021	CS-9	ROOM 118	6.02
Clifton School	7/25/2021	8/02/2021	CS-10	ROOM 119	17.9
Clifton School	7/25/2021	8/02/2021	CS-11	ROOM 121	38.4
Clifton School	7/25/2021	8/02/2021	CS-12	ROOM 126	<1.00
Clifton School	7/25/2021	8/02/2021	CS-13	ROOM 128	<1.00
Clifton School	7/25/2021	8/02/2021	CS-14	ROOM 129	<1.00
Clifton School	7/25/2021	8/02/2021	CS-15	ROOM 130	<1.00
Clifton School	7/25/2021	8/02/2021	CS-16	WF BY GYM	<1.00
Clifton School	7/25/2021	8/02/2021	CS-17	ROOM 226	<1.00
Clifton School	7/25/2021	8/02/2021	CS-18	ROOM 227	<1.00
Clifton School	7/25/2021	8/02/2021	CS-19	ROOM 225	<1.00
Clifton School	7/25/2021	8/02/2021	CS-20	ROOM 224	<1.00
Clifton School	7/25/2021	8/02/2021	CS-21	ROOM 223	<1.00
Clifton School	7/25/2021	8/02/2021	CS-22	WF BY ROOM 219	23.8
Clifton School	7/25/2021	8/02/2021	CS-23	ROOM 216	3.30
Clifton School	7/25/2021	8/02/2021	CS-24	ROOM 213	6.17
Clifton School	7/25/2021	8/02/2021	CS-25	WF BY ROOM 203	17.1

Building	Date Collected	Analysis Date	Sample ID	Sample Description	Concentration (ug/L) Or ppb
Clifton Avenue School					
Clifton School	7/25/2021	8/02/2021	CS-26	STADIUM DF 101 (Quality Control)	<1.00
Clifton School	7/25/2021	8/02/2021	CS-1	BY ROOM 106	<1.00

Appendix D Floor Plan(s)

Appendix E Laboratory Data